



- 3phase 35kV (336 AC5R)
- 3phase 12.5kV (110 AC5R)
- N with fiber lashed (4/0 AC5R)

MORRISON

- Replace red tagged pole + guying, replacement pole is 50/13
- Pole from E 60 20/13 = 40'

Top 130N
PMB 29W
StC 3Z
NW NW

- 3 phase 35kV (336 ACsr)
- 3 phase 12.5kV (110 ACsr)
- N with fiber lashed (4/0 ACsr)

WO # S241058