

PROJECT OVERVIEW

NEW SVC W/O #54705476
 INSTALL 6" X 1-1/4" TR SVC TEE. INSTALL APPROX 275' OF 1-1/4" TR SVC LINE.
 INSTALL 1-1/4" ANODELESS RISER W/ BYPASS.
 SVC EQUIP #55306874
 TAP @ 27' WCL COUNTRY 213 & APPROX 370' SCL 5 AVE NW.

NOTE: BORE ALL PAVED STREETS AND DRIVEWAYS
 Minimum depth requirements for pneumagopher crossings of state highways and county roads is 60". Minimum depth requirements for pneumagopher crossings of city streets and township roads is 48". Minimum depth for parallel installations on state highways and county roads is 36". Minimum depth for parallel installations on city streets and township roads is 30".

COUNTY RD 213 (PAUL LARSON MEM DR)


TO HIGHWAY 27

F2757 2001 6" TR CL-6


27'

100'

TO COUNTY RD 201



5 AVE NW



FSV METER W/O #54608645
 SEE MOVE IN #54705317. INSTALL 7MTC VIRGIL
 METERSET W/ 2" CLASS 6 B34R REG @ 2PSIG W/
 1/2" ORIFICE (7374cfh). INSTALL 2" 289H RELIEF @
 3PSIG. INSTALL METERSET BYPASS. METER TO
 GO AT APPROX 15' SNBL ON WEST WALL.



PROPRIETARY AND CONFIDENTIAL

54705476

M16000 LITTLE FALLS

ONE CALL:

Morrison

*SE18 T129/R29

* = this Page

Legend	Interruptible
Abandon	Existing
Proposed Abandon	Normal
Designed	Active, High
Active, High	Future
Active, Low	Proposed

Address: 700 PAUL LARSON MEM DR BLDG 6A
 Customer: LARSON BOATS
 Contact Person: DAN RYAN
 Contact Phone: 320-980-1940
 Sales Rep: SHELLY HOODE
 Sales Rep Phone: 320-808-8630
 Copies To Pipeline Integrity: No
 Customer Service Valve: No
 Copies to Corrosion: No
 Corrosion Approval: N/A
 Permits: MORRISON COUNTY
 Requested Install Date: 07/25/2010
 Maps: 4-18

Approval: _____

PROJECT DESCRIPTION:
 LARSON BOATS

DESIGNER: Aaron Jacobs
 PHONE #: 612-321-5569
 DRAWN BY: Aaron Jacobs
 DESIGN DATE: 6/28/2010

Revised Print
 Destroy All Others
 Revision History
 Date: 7/14/2010
 Description: METER LOC MOVED.
 Design Approval: _____

IC Services 1":80'
 SCAN DATE: SHEET 1 OF 1