



4	
Ext	291 1/0 ACSR
Ext	873 4/0 ACSR
Ext	1 40-4
Ext	1 C1.11P
Ext	1 H1.1
Ext	1 TANTALUS TR REPEATER
New	1 G9-1

MOVE TANTALUS REPEATER AND
XFMR TO NEXT POLE TO THE NORTH

USING C6.52 SPEC FOR CHARGING OUT MATERIAL
USE 10' ARMS ON DEAD END - PLACE ALL PHASES
AND NEUTRAL ON ARMS TO KEEP CLEARANCE

1	
Ext	282 1/0 ACSR
Ext	846 4/0 ACSR
Ext	1 45-4
Ext	1 C1.11P
Ext	1 E1.1
Ext	1 F2.8
Ext	1 H1.1
Ext	1 S1.01
New	1 C6.52
New	2 S1.01 A & B PHASE
Ret	1 A5.21
Ret	1 G9-3

54-000-34-08408
TR#0075 NEXT TO 36084 BUGLE RD

54-000-34-08409
36084 BUGLE ROAD - EAST FARM HOUSE

54-000-34-08400
36084 BUGLE RD

MOUNT (3) NEW CT'S & CT METER LOOP TO POLE
ELECTRICIAN WILL BURY (3) RUNS OF 250MCM IN CONDUIT
FROM NEW POLE TO DISCONNECTS ON WALL OF SHED

3	
Ret	1 40-5
Ret	1 A2.21
Ret	1 H1.1

2	
Ext	720 4 ACSR
New	360 4 ACSR A & B PHASES
New	1 40-5
New	1 C5.21
New	1 CT THREE PHASE
New	1 E1.1
New	1 E1.5
New	1 F2.8
New	1 G3.3 120/208V 25KVA TUBS
New	1 H1.1
New	1 L1.5
New	1 L2.5
New	1 OWNER LOOP CT METER LOOP

2A	
Ext	42 250 MCM USE(3) RUNS MEMBER OWNED
New	1 CONS-UG