

3rd meter on site 875

John Deere / grower

Woodland-Shop
2244 22nd Ave.
(320) 547-2336 or 360-5379

W.O. #


18-SC-SW-81-SWS-5194

128A-31W-SECT 5

ADDRESS

Include street name and any cross streets

N



2 PE

Pipe & Fitting Type ☒ High D ☐ Medium D

Material List	Lot #	Qty
Pipe 5/8" or 1"	See Remarks	
Tee 2x5/8 or 2x1	306197	1
Tee 4x5/8 or 4x1		
Tee 6x5/8 or 6x1		
EFV 5/8 or 1"	13171	1
2, 5, 10 or 12 # Meter Bar		1
Cplg 5/8 or 1 or 2"	Bracket post Foundn.	1
Split Bolt	Riser 5/8 or 1"	1
5/8 or 1" ELL	Cap 5/8 or 1"	
PE Tee 5/8 or 1"	PE Reducer 5/8x1"	1
Carsonite	Anode 3#	
# of Heaters	Restoration Y ☒ N ☐	

Meter

Locked ☐ Unlocked ☒

Size 275 Location East

MFG Sensus Reading 0000

New Meter # 18033003

Reg. Type/Press. 2# 5# 10# 12#

Old Meter# _____

Old Meter Reading: _____

Does Winter Construction Apply? Y ☐ N ☐

Condition of Existing Pipe

	Outside	Inside	Coating
Good	☐	☐	☐
Fair	☐	☐	☐
Bad	☐	☐	☐
Anode # _____	MV Reading _____		

Description	Install Footage
Directional Bore	
Pneumatic Bore	
Backhoe	
Inserting	
Trench	
Plow	
Hand Digging	
Joint Trench	
Gopher Pipe	
Cust. Perf. Loc.	

Permit Required Y ☐ N ☐

Remarks:

1" PE CEE ASTM D2513 N2B58m 1025D 10 Aug 12 coil 000291

Existing Main	
Size <u>2</u>	Pressure <u>100</u> Type/Mfr <u>Dura-Line</u>
Lot # <u>-</u>	Cover <u>36</u> Location <u>-</u>
New Service / Main	
Size <u>1</u>	Lot # <u>See Remarks</u>
Poly Mfr <u>Dura-Line</u>	Nature of Soil <u>Sandy clay</u>
Tap Size <u>-</u>	Cover <u>30</u> Completion Date <u>11-20-13</u>
Foreman ID <u>5578</u>	Welder/Fuser ID <u>7945</u>
Pressure Test	
Test With: Air / <u>Nitrogen</u>	Duration <u>30</u> Emp ID <u>7945</u>
Date Tested <u>11-20-13</u>	PSI <u>152</u> Soap Test Final Tie-in? Y ☒ N ☐
Filled out by Mapping Dept.	
Mapped in System Maps _____	Date _____
Mapped in GIS _____	Date _____
Entry Person _____	Date _____
GSOC Polygon Available Yes ☐ No ☐	



SCANNED