

COVERSHEET



17330 MN-371
Brainerd, MN 56401
(218) - 829 - 2827

RUS Code:	W/O #:	429095
EXT 740 C:	WP #:	
Loan Nbr: BB8	LOC #:	76-000-14-04803
Loan Ywr: 2017	Name:	MICHAEL J KAPSNER
AFF #:	(H) Phone #:	4682606
Elec:	(W) Phone #:	
RFCd:	(C) Phone #:	
By:	Acct #:	

City:	Staked By:	LUKE M KASELLA
Sec: 15	Date:	10/17/2017 12:00:00AM
Twp: 41	Signed By:	
Rg: 29	Date:	10/17/2017

Tailgate Session

Job Steps:	Work Procedures:
PPE Needed:	Job Hazards:
Source Control Verified/Size:	Equipment Needed:
Personal Tools:	1-Shot/K-Fuse Size:
Crew:	Date:
Comments:	

Gopher State

Locate #:	Date OK:
-----------	----------

Comments 1:
Comments 2: SEND INVOICE TO MORRISON COUNTY FOR \$3750-REFERENCE CO RD 268 BRIDGE REPLACEMENT
Comments 3:

Septic:	Row 1:	Rd Permit:	✓
Priv Elec:	Row 2:	Cty Permit:	
LP Line:	Line Ext \$ Bore/Push \$ Permit \$	Ped/Loop \$ Total \$	Fees:
Sprinkler:	Backfill Comments:		TWP Permit:
Final Grade:			State Permit:
Brushing:			DNR Permit:
Trees:			Joint Trench:
Easements:			Notify TWP:

Type of Device: Fuse	Size of Device: FUS-10T	Box/Switch #:
----------------------	-------------------------	---------------

Reel ID:	Start Ftg:	End Ftg:
Reel ID:	Start Ftg:	End Ftg:
Reel ID:	Start Ftg:	End Ftg:

CONDUCTOR SUMMARY

STATUS	CONDUCTOR	TYPE	QTY (FT)
	1/0 25KV JAC	PRIMARY	789
INSTALL	1/0 15KV JAC 220 MIL	PRIMARY	1995
	4 ACSR	PRIMARY	1560
INSTALL	2 INNERDUCT	SECONDARY	102



330th Ave

STAND OFF NEW CABLE FROM THE
NORTH TO CREATE NEW OPEN POINT

2
45' CL

1

1.1

76-000-14-04803
18484 330TH AVE

25KV NONJACKET CABLE

2
102' BORE
New 102 2 INNERDUCT

1
Ext 916 1/0 25KV SOL
Ext 1 UM27-2
New 22 15KV 1/0 SOLID (JACKET) 220 MIL
New 1 UG7-15
New 2 UM6-1
New 1 UM6-15-15
New 1 UM6-34
Ret 1 UG7-10 B9129 RANCH RUNNER
Ret 1 UM6-1
Ret 1 UM6-10-25

1.1
NEW OPEN POINT
New 1973 15KV 1/0 SOLID (JACKET) 220 MIL



CHANGE LINE FROM NORTH TO
'C' PHASE AT 3 PHASE LINE ON HWY 27

3	Ext 818 1/0 25KV JAC
New	1 UM27-2
New	1 UM3-14
New	4 UM6-1
New	1 UM6-22-15

4	Ext 1 40-5
Ext	1 A5.1
Ext	1 E1.1
Ext	1 F2.8
Ext	1 H1.1
Ext	1 UA3 10T FUSE

-INSTALL EXISTING SOURCE AND TAP
RISERS ON POLE IN TO NEW 10 BOX
-ADD NEW RISER TO POLE WITH 10T FUSE
TO FEED THE TAP ACROSS THE ROAD

